

- +12 VDC applied to DSE890 M2II
 - 20 Feb installed PC52 at SSR desk
 - set TCP/IP v4 properties to 192.168.1.99
 - w/ Firefox browsed to 192.168.1.100 w/
 - logged on Admin password 1234
 - successfully into DSE 0890-04 Gateway screen
 - Apply on Set Password
 - Clicked Save Configuration
 - forced to chg password
 - Admin
 - PI2T (cps)
 - this got to main screen w/ all tabs
 - noted: Gateway ID 1912ED17B3AAC44
 - Software ver 4.3.2
 - Bootloader 1.1.2
 - put in USB cable w/ 2 permits. Now Network tab = gateway shows:
 - IP Static
 - IP Addr 192.168.1.100 255.255.255.0 DNS 8.8.8.8
 - Gateway IP address 192.168.1.253
 - web port 80
 - MAC Address E8A4C116AC44
 - Hostname DSEGateway46

← this is hard-set in the gateway firmware
 - connected Ethernet cable for Gateway to Seica router
 - no apparent activity
 - Connected Ethernet cable to ASUS Router
- (Note: I had to turn on the controller w/ the key to get USB traffic. Now led lite solid red, USB lite blinking green.) USB data t/c OK.
- See data t/c on ASUS Router port 4